


**SECTION A-A**

**NOTES:**

1. TERMINATE ALL PIPES FLUSH WITH INSIDE WALL OF MANHOLE.
2. CHANNELS TO BE FORMED TO APPROXIMATE WIDTH, SIZE AND SHAPE, OF PIPE AND FINISHED WITH GROUT. THICKNESS OF GROUT TO BE APPROXIMATELY ONE HALF INCH (1/2"). CONTINUE SLOPE OF PIPE THROUGH MANHOLE, 2% MINIMUM SLOPE.
3. WHEN FOUR (4) LINES COME INTO A MANHOLE, THE TWO LINES WHICH EMPTY INTO THE MAIN CHANNEL ARE TO BE STAGGERED AND NOT SET SO THEY WILL EMPTY IN AT THE SAME POINT.
4. ALL CONCRETE TO BE SIX (6) SACK.



TITTLE			<b>SANITARY SEWER MANHOLE</b>		
ADOPTED BY CITY COUNCIL DATE:		SCALE: NONE	<b>SS-1</b>		
1/13/2011		DATE: 1/4/2011			
		CHK: RC			
26379 FREMONT ROAD, LOS ALTOS HILLS, CA 94022 • Phone: (650) 941-7222					