



NOTE:

1. SEWER LATERAL FROM THE HOUSE SHALL BE CONSTRUCTED PER BUILDING DEPARTMENT REQUIREMENTS.
2. IN DRIVEWAY OR PLANTED AREA, USE CHRISTY TYPE G5 TRAFFIC BOX WITH G5C LID OR EQUAL. LID SHALL CONTAIN THE LETTERS "SEWER".
3. WHEN INSTALLED IN PLANTED AREAS, CLEANOUT BOX SHALL BE SET A MINIMUM OF 1-1/2" ABOVE GRADE.
4. OWNER IS RESPONSIBLE FOR MAINTENANCE, REPAIR, AND REPLACE OF LATERAL, FROM THE BUILDING TO THE MAIN CONNECTION INCLUDING THE WYE AT THE MAIN, SEWER RELIEF VALVE AND BACKFLOW PREVENTOR.
5. INSTALL BACKFLOW PREVENTOR "CLEAN CHECK" EXTENDABLE BACKWATER VALVE, OR APPROVED EQUAL, UPSTREAM OF PROPERTY LINE CLEANOUT.

LOS ALTOS HILLS



CALIFORNIA

TITLE

VERTICAL SEWER LATERAL CLEANOUT

ADOPTED BY CITY COUNCIL DATE:

1/13/2011

SCALE: NONE

DATE: 1/6/2011

CHK: RC

STANDARD DETAIL

SS-6